Lead in School Drinking Water Report

Geneva Elementary School



Date(s) collected: 2023-11-16
Date(s) analyzed: 2024-01-05, 2024-01-06, 2024-01-08

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386824	Main Building	Fountain/Tap Combo	Rm5	Only sink	Tap	240
386829	Main Building	Fountain/Tap Combo	Rm7	Only sink	Water Fountain	32
386828	Main Building	Fountain/Tap Combo	Rm7	Only sink	Tap	27
386810	Main Building	Fountain/Tap Combo	Classroom Off Cafeteria	Only sink	Tap	26
386814	Main Building	Fountain/Tap Combo	Cafeteria	Left of custodian office	Tap	23
386820	Main Building	Fountain/Tap Combo	Rm3	Only sink	Tap	20
386838	Main Building	Fountain/Tap Combo	Rm11	Only sink	Tap	20
386840	Main	Fountain/Tap	Rm12	Only sink	Tap	20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building	Combo				
386854	Main Building	Fountain/Tap Combo	Rm23	Only sink	Tap	6
386140	Main Building	Fountain/Tap Combo	Rm20-			