

Date(s) collected: 2023-11-03
Date(s) analyzed: 2023-12-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386236	Main Building	Sink	Floor1 Rm1	Only sink	Tap	<1
386237	Main Building	Sink	Floor1 Rm4	Only sink	Tap	<1
386238	Main Building	Fountain	Floor1 Hallway	Right of rm4	Water Fountain	<1
386239	Main Building	Sink	Floor1 Office	Only sink	Tap	<1
386240	Main Building				Water Fountain	<1

Sample ID	Building Name	Fixture
--------------	------------------	---------