

Date(s) collected: 2023-11-07

Date(s) analyzed: 2023-12-29, 2023-11-30

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386255	Main Building	Fountain/Tap Combo	Rm10	Only sink	Water Fountain	60
386113	Main Building	Fountain/Tap Combo	Rm6	Only sink	Tap	28
386256						

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386125	Main Building	Sink	Rm12	Only sink	Tap	7
386254	Main Building	Fountain	Hallway	Left of girls restroom	Water Fountain	7
386109	Main Building	Fountain/Tap Combo	Rm5	Only sink	Tap	6
386251	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Outside Cafeteria	1 of 2	Water Fountain	6
386252	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Outside Cafeteria	2 of 2	Water Fountain	6
386103	Main Building	Fountain/Tap Combo	Rm4	Only sink	Tap	5
386258	Main Building	Sink	Rm1	Only sink	Tap	5
386259	Main Building	Fountain/Tap Combo	Rm2	Only sink	Tap	5
386101	Main Building	Fountain/Tap Combo	Rm3	Only sink	Tap	4
386111	Main Building	Fountain/Tap Combo	Rm5	Only sink	Water Fountain	3
386250	Main Building	Sink - Multi-Compartment	Kitchen	Food prep sink	Tap	3
386100	Main Building	Fountain/Tap Combo	Rm2	Only sink	Water Fountain	2
386102	Main Building	Fountain/Tap Combo	Rm3	Only sink	Water Fountain	2
386117	Main Building	Fountain/Tap Combo	Rm7	Only sink	Tap	1
386107	Main Building	Fountain/Tap Combo	Rm4	Only sink	Water Fountain	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
386121	Main Building	Combo Sink	Rm8	Inner classroom, non-bathroom/handwashing	Fountain Tap	<1