

School Name: Northern Heights Elementary

School District: Bellingham Public Schools

County: Whatcom County

	5/19/2023	6/27/2023	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other:

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

Northern Heights has identified 3 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with mitigation measures are repeated in the table below.)

have been or will be implemented as follows:

1)	5/19/2023	37393 4	Room 105	Sink faucet	13	Replacement	TBD
2)	5/29/2023	37385 2	Kitchen	Largest 2 tier sink faucet	9	Replacement	TBD

