

Lead in School Drinking Water Report

Wade King Elementary School



Date(s) collected: 2023-05-18

Date(s) analyzed: 2023-05-24

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|-----------|---------------|----------------------|-----------------------------|--------------------------|--------------------|------------------------|
| 374002 | Main Building | Sink | Room 3 | Only sink | Tap | 19 |
| 374005 | Main Building | Sink | Room 1 | Only sink | | |
| 374008 | Main Building | Sink | Mrs Hagin Room Chinese. Old | Only sink | Water Fountain Tap | 2 |

Sample
ID

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|-----------|---------------|------------------------|---------------------|------------------------------------|----------------|------------------------|
| 374003 | Main Building | Sink | Room 3 | Only sink | Water Fountain | <1 |
| 374006 | Main Building | Fountain - Multi-Level | 2nd Floor Fountains | Next to restrooms. Higher fountain | Water Fountain | <1 |
| 374007 | Main Building | Fountain - Multi-Level | 2nd Floor Fountains | Near restrooms | Water Fountain | <1 |
| 374010 | Main Building | Sink | Room 21 | Only sink | Tap | <1 |
| 374011 | Main Building | Sink | Room 21 | Only sink | Water Fountain | <1 |
| 374012 | Main Building | Sink | Room 22 | Only sink | Tap | <1 |
| 374014 | Main Building | Sink | Room 24 | Only sink | Tap | <1 |
| 374015 | Main Building | Sink | Room 24 | Only sink | Water Fountain | <1 |
| 374016 | Main Building | Sink | Room 25 | Only sink | Tap | <1 |
| 374018 | Main Building | Sink | Room 27 | Only sink | Tap | <1 |

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: