

12/27/22

Date(s) collected: 2022-10-12, 2022-10-13

Date(s) analyzed: 2022-10-18

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
375161	Main Building	Sink - Multi-Compartment	Kitchen	Dishwasher	Tap	3

Sample ID	Building
--------------	----------

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
375189	Main Building	Fountain/Tap Combo	B19	Single-Ftn not working	Tap	1
375190	Main Building	Fountain/Tap Combo	B 18	Single Ftn not working	Tap	1
375191	Main Building	Fountain/Tap Combo	B15	Single	Water Fountain	2
375192	Main Building	Fountain/Tap Combo	B15	Single	Tap	1
375193	Main Building	Fountain/Tap Combo	B14	Single	Tap	1
375194	Main Building	Fountain/Tap Combo	B14	Single	Water Fountain	5
375195	Main Building	Fountain/Tap Combo	B09	Single	Tap	1
375196	Main Building	Fountain/Tap Combo	B11	Single Ftn not work	Tap	1
375197	Main Building	Sink	B13	S wall far left	Tap	2
375198	Main Building	Sink	B13	S wall	Tap	2
375199	Main Building	Sink	B13 S Wall	3rd from left	Tap	1
375200	Main Building	Sink	B13	Wrk rm	Tap	4
375201	Main Building	Sink	B13	Corner single station s wall	Tap	1
375202	Main Building	Sink	B13	N wall far left	Tap	2
375203	Main Building	Sink	B13 N Wall	2nd from left	Tap	2
375204	Main Building	Sink	B13 N Wall	Middle of 5	Tap	2
375205	Main Building	Sink	B13 N Wall	2nd from right	Tap	2
375206	Main Building	Sink	N Wall B13	Far right	Tap	1



Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building			right		
375226	Main Building	Fountain/Tap Combo	104	Single Ftn not work	Tap	1
375227	Main Building	Fountain/Tap Combo	103	Single	Tap	1
375228	Main Building	Fountain/Tap Combo	103	Single	Water Fountain	1
375229	Main Building	Fountain/Tap Combo	102	Single	Tap	1
375230	Main Building	Fountain/Tap Combo	102	Single	Water Fountain	1
375231	Main Building	Fountain/Tap Combo	101	Single	Tap	1
375232	Main Building	Fountain/Tap Combo	101	Single	Water Fountain	3
375233	Main Building	Fountain/Tap Combo	135	Single	Tap	1
375234	Main Building	Fountain/Tap Combo	135	Single	Water Fountain	2
375235	Main Building	Sink	136	S wall left	Tap	2
375236	Main Building	Sink	136	S wall 2nd fm left	Tap	3
375237	Main Building	Sink	136	S wall middle of 5	Tap	2
375238	Main Building	Sink	136	S wall 2nd from right	Tap	4
375239	Main Building	Sink	136	S wall far right	Tap	6
375240	Main Building	Sink	136	N wall far left	Tap	3
375241	Main Building	Sink	136	Back wrk rm	Tap	3
375242	Main Building	Sink	136	N wall 2nd fm left	Tap	3
375243	Main Building	Sink	136	2nd to rt N wall	Tap	2

Sample ID	Building Name
--------------	------------------